

CITY OF DAHLONEGA

465 Riley Road
Dahlonega, Georgia 30533
Phone: 706-864-6133 • Fax: 706-864-4837

DESIGN, EQUIPMENT, AND INSTALLATION OUTDOOR WIRELESS SOUND SYSTEM #2023-002

ADDENDUM 3

Addendum Issue Date: March 14th, 2023

Addendum Subject: Q&A, Supporting Attachments

Addendum Page Numbers: 2

Proposers must take due notice and be governed accordingly. The addendum must be acknowledged as indicated in the Request for Proposal or your Proposal may not be considered.

Questions and Answers

- 1. Confirm city can provide 110VAC power for each metal city owned light pole plus one wooden one with streetlight by Hancock Park pavilion.

 Yes, 110VAC power will be provided to each light pole. The City requests the speaker(s) for Hancock Park be attached to the Hancock Park Pavilion. Power is available at the pavilion.
- 2. Confirm ok for contractor to attach speakers to city owned street lights.

 Georgia Power owns all the light poles shown in Attachment 1. The City and Georgia Power will sign an agreement for the use of the light poles.

Other

The City of Dahlonega requests vendors include the dimensions and weight of any speakers proposed for installation in their proposals. These dimensions and weight will have to be approved by Georgia Power prior to any equipment installation.

Please include the cost of installation in your proposals. City employees will be unable to assist in installing speakers to the light poles and pavilion.

Attachment 1: Map of Georgia Power owned light poles in the downtown area. Green is marked for location of light poles and possible locations for speakers. Brown is marked for the location of distribution poles.

Attachment 2: Map of conduit and pull boxes in the downtown area.



