



CITY OF DAHLONEGA
465 Riley Road
Dahlonega, Georgia 30533
Phone: 706-864-6133 • Fax: 706-864-4837

**MECHANICSVILLE RD CURB AND GUTTER
PROJECT #2023-004**

ADDENDUM 1

Addendum Issue Date: March 23rd, 2023

Addendum Subject: Q/A, Revised Attachment D and Contract Page

Addendum Page Numbers: 3

Bidders must take due notice and be governed accordingly. The addendum must be acknowledged as indicated in the Invitation to Bid or your Bid may not be considered.

Questions and Answers

1. Who is to repave the section of asphalt to be demo?
The valley gutter shall be tied into the existing asphalt per plans.
2. No bid items for Class A concrete to fill voids
This shall be included in the price of curb and gutter.
3. Do you need a shoulder behind curb or is the slope from back of curb?
The slope should be at a 4:1 or flatter as per plans.
4. Do you need GAB in pavement area?
Concrete shall be placed on 6" of GAB.
5. How thick should the concrete valley gutter be on this project? Specifications on page 6 of 24, item number 441-4020 conc valley gutter 6 in. Plans dated 12-14-22 page 2 has typical valley gutter detail states 6" minimum thickness class A concrete. Bid form page 19 of 24, item # 0030 concrete valley gutter 8 in.
The plans are correct, the concrete shall be at a depth of 6 inches.
6. Upon visiting the area/road, the existing asphalt at the edge of the pavement and driveway entrances appear to be alligatored (deteriorating). There likely will not be a way to maintain its integrity when saw cutting and the removal of asphalt. With all this taken into account, what is the plan if remediation is needed?
The plans (sheet one) call for the two lower driveways to have the asphalt removed and pour valley gutter in place. The City Public Works personnel will mark the limits of the driveways to be cut out.

ATTACHMENT D
MECHANICSVILLE RD CURB AND GUTTER
PROJECT # 2023-004

PRICING SHEET

Company Name: _____

| LINE NUMBER | ITEM DESCRIPTION | ESTIMATED QUANTITY AND UNITS | UNIT PRICE (DOLLARS/CENTS) | DOLLARS/CENTS |
|------------------|---|------------------------------|----------------------------|---------------|
| 0005 | 150-1000 Traffic Control | 1 Lump Sum | | |
| 0010 | Construct and Maintenance Miscellaneous Erosion Control Items | 1 Lump Sum | | |
| 0015 | 207-0204 Found Backfill Matl, TP 2 | 35 TN | | |
| 0020 | 210-0100 Grading Complete Incl Demo | 1 Lump Sum | | |
| 0025 | 310-1101 Graded Aggregate Base Crs 6 IN | 40 TN | | |
| 0030 | 441-4030 Concrete Valley Gutter, 6 IN | 100 SY | | |
| 0035 | 441-6012 Concrete Curb & Gutter, 6 IN x 24 IN, TP 2 | 720 LF | | |
| 0040 | 550-1360 Storm Drain Pipe 36 IN. H 1- 10 HDPE n-12 Smooth Wall | 40 FT | | |
| 0045 | 668-1100 Catch Bason, GP 1, 1033 | 1 EA | | |
| 0050 | 668-2100 Drop Inlet, W/ Pedestal Top and Collar | 1 EA | | |
| 0055 | 700 Grassing Complete | .5 AC | | |
| TOTAL BID | | | | |

I certify the above bid as all-inclusive and final per document specifications.

Authorized Signature

Title

Print Name

Date

CERTIFICATION SIGNATURES FOR ATTACHMENT D

5. Contractor shall be paid for work performed under this Contract on a unit price basis as follows:

| LINE NUMBER | ITEM DESCRIPTION | UNIT OF MEASURE | UNIT PRICE (DOLLARS/CENTS) |
|-------------|--|-----------------|----------------------------|
| 0005 | 150-1000 Traffic Control | Lump Sum | \$ |
| 0010 | Construct and Maintenance of Miscellaneous Erosion Control Items | Lump Sum | \$ |
| 0015 | 207-0204 Found Backfill Matl, TP 2 | TN | \$ |
| 0020 | 210-0100 Grading Complete incl Demo | Lump Sum | \$ |
| 0025 | 310-1101 Graded Aggregate Base Crs 6 In | Ton | \$ |
| 0030 | 441-4030 Concrete Valley Gutter, 6 IN | SY | \$ |
| 0035 | 441-6012 Concrete Curb & Gutter, 6 IN x 24 IN, TP 2 | LF | \$ |
| 0040 | 550-1360 Strom Drain Pipe 36 IN H 1-10 HDPE n-12 Smooth Wall | FT | \$ |
| 0045 | 668-1100 Catch Bason, GP1,1033 | EA | \$ |
| 0050 | 668-2100 Drop Inlet, W/Pedestal Top and Collar | EA | \$ |
| 0055 | 700 Grassing Complete | AC | \$ |

Payment shall be made according to the terms contained in the Invitation to Bid.

B. Bonds:

Contractor shall, prior to commencing work, provide and shall maintain, during the continuance of all work under the Contract, all Bonds required in the Invitation to Bid.

C. Liability:

Contractor shall be responsible for his work and every part thereof, and for all materials, tools, equipment, appliances, and properties of any and all description used in connection with this Contract.

Contractor assumes all risks of direct and indirect damage or injury to the property of persons used or employed on or in connection with the work contracted for, and of all damage or injury to any person or property wherever located, resulting from any action, omission, commission or operation under the Contract, or in connection in any way whatsoever with the contracted work.