



**CITY OF DAHLONEGA**  
465 Riley Road  
Dahlonega, Georgia 30533  
Phone: 706-864-6133 • Fax: 706-864-4837

---

**ASPHALT LEVELING AND RESURFACING CITY STREETS IN  
DAHLONEGA, GEORGIA LMIG PROJECT #2024-001**

**ADDENDUM 1**

Addendum Issue Date: January 19th, 2024

Addendum Subject: Q/A

Addendum Page Numbers: 1

***Bidders must take due notice and be governed accordingly. The addendum must be acknowledged as indicated in the Invitation to Bid or your Bid may not be considered.***

**Questions and Answers**

1. There is no striping required on either project, correct? (2024-001 & 2024-002)  
**Striping is not required on either project. Contractor shall place centerline tape.**
2. Are tripod mounted signs okay?  
**Yes.**
3. Are post mounted low/soft shoulder signs required?  
**Yes. Low/soft shoulder signs shall be post mounted.**
4. There is to be no shoulder building, correct?  
**This contract does not include shoulder building.**